

TYPE EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFTS LANDING DOORS

Issued by Liftinstituut B.V.

- Certificate no. : NL15-400-1002-205-01 Revision no.: 2
- Description of the product : Fire resistant two panel central opening lift landing door
- Trademark, type : Central Opening Lift Landing Door – MRT
- Name and address of the manufacturer : Emay Kalip Mekine Müh. Asansör San. Tic. Ltd. Şti
Hasanağa Organize San.Böl.Hosab Cad.No:33
Nilüfer – Bursa – Turkey
- Name and address of the certificate holder : Emay Kalip Mekine Müh. Asansör San. Tic. Ltd. Şti
Hasanağa Organize San.Böl.Hosab Cad.No:33
Nilüfer – Bursa – Turkey
- Certificate issued on the following requirements : Lifts Directive 2014/33/EU
- Certificate based on the following standard : EN 81-58:2003
- Test laboratory : Efectis Era Avrasya A.Ş.
- Date and number of the laboratory report : 24-08-2015; RFTR15105
- Date of type examination : 23-06-2015; Rev.1, 05-10-2015;
Rev.2, 08-11-2017
- Classification :

The performance criteria of the EN 81-58 covered are:			
	E	EI	EW
Central Opening Landing door MRT	120	90	60
- Additional document with this certificate : Report belonging to the type examination certificate no.: NL15-400-1002-205-01 rev.2
- Additional remarks : None
- Conclusion : The landing door MRT meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.

Amsterdam

Date : 08-11-2017
Valid until : 08-11-2022

ing. P.J. Peeters
Manager

Certification decision by

Report Type-examination

Report belonging to type-examination certificate no. : NL15-400-1002-205-01
Date of issue of original certificate : September 11, 2015
Number and date revision : 2; November 8, 2017
Requirements : Lifts Directive 2014/33/EU
Standards: EN 81-58:2003
Project no. : P170384

1. Examinations and tests

The type examination of the two panel central opening lift landing door MRT existed from assessing the technical file and laboratory test report. The test was executed on 23-06-2015 at Efectis Era Avrasya, Turkey. All results for fire resistance are described in Efectis report no. RFTR15105. Liftinstituut recognizes the test and results. Report RFTR15105 is part of this examination (see annex 2).

2. Results

After the final test the fire resistance results of the lift landing door were ranked in accordance with the requirements (classification) of the standard EN 81-58. See report RFTR15105 Chapter 10 for field of direct application of test results.

3. Conclusions

Based upon the results of the type-examination, Liftinstituut B.V. issues a type-examination certificate for the fire resistance of the Emay two panel central opening lift landing door MRT.

The type-examination certificate is only valid for products which are in conformity with the same specifications as the type-certified product. Products deviating of these specifications need additional examination by Liftinstituut in order to determine whether a new type-examination certificate is necessary. Additional examination shall be requested by the certificate holder.

The type examination certificate is issued based on the requirements that are valid at the date of issue. The manufacturer shall request from Liftinstituut B.V. the review of the validity of the EC-type examination certificate, taking into account the changes in the requirements or changes in the state of the art of the product, every 5 years.

Prepared by:



P. J. Schaareman
Product Specialist Certification
Liftinstituut B.V.

Certification decision by:





Annexes

Annex 1 : Overview of revisions

Rev.:	Date	Summary of revision
-	11-09-2015	Original
1	05-11-2015	Editorial correction in report
2	08-11-2017	Update to new Lift Directive 2014/33/EU

Annex 2 : Report RFTR15105

Report Efectis Era Avrasya, 27 pages.