

TYPE-EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFT LANDING DOORS

Issued by Liftinstituut B.V.

Certificate no. : NL15-400-1002-205-01 Revision no. -
Description of the product : Fire resistant two panel central opening lift landing door
Trademark, type : Central Opening Lift Landing Door – MRT
Name and address of the manufacturer : Emay Kalip Mekine Müh. Asansör San. Tic. Ltd. Şti
Hasanağa Organize San.Böl.Hosab Cad.No:33
Nilüfer – Bursa – Turkey
Name and address of the certificate holder : Emay Kalip Mekine Müh. Asansör San. Tic. Ltd. Şti
Hasanağa Organize San.Böl.Hosab Cad.No:33
Nilüfer – Bursa – Turkey
Certificate issued on the following standards : Lifts Directive 95/16/EC
Certificate based on the following standards : EN 81-58:2003
Test laboratory : Efectis Era Avrasya A.Ş.
Date and number of the laboratory report : 24-08-2015; RFTR15105
Date of type-examination : 23-06-2015


Classification : The performance criteria of the EN 81-58 covered are:

	E	EI	EW
Emay, Central Opening Landing door MRT	120	90	60

Additional document with this certificate : Report belonging to the type-examination certificate;
No: NL15-400-1002-205-01

Additional remarks : -

Conclusion : The Emay lift landing door MRT meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.



Issued in Amsterdam
Date of issue : 11-09-2015
Valid until : 31-08-2017

ing. A.J. van Ommen
Manager Business Unit
Certification

Certification decision by

